



WSIPC ITB #26-06-01 Boiler Purchase, Removal, and Installation Addendum 4

July 2, 2026

The following corrections, questions, and clarifications are provided concerning WSIPC ITB #26-06-01 Boiler Purchase, Removal, and Installation. Paraphrasing any relevant questions posed to the WSIPC RFP Contract Administrator have been included as appropriate.

Q1 – Can you provide your Vendor POC for the NCS Control System?

A1 – 1) Cody Willemin | Account/Sales Executive | NCS Corporation cwillemin@ncs-corp.com
2) Tom Willemin | CEO | NCS Corporation tomwill@ncs-corp.com

Q2 – What is the reason for replacing the Emergency Boiler Shut off Switch?

A2 – Washington Boiler and pressure vessel law requires shutoff of fuel supply to the boilers.

Q3 – Is this loop chemically treated?

A3 – Yes, it is treated

Q4 – What is WSIPC's work schedule for this project, and do you allow for early start times like 7:00, or 7:30AM?

A4 – Refer to ITB 26-06-01 Solicitation Document

SECTION 4: Specifications and Scope of Services

4. Work Hours:

Contractor shall propose work hours and a detailed schedule sufficient to achieve substantial completion of boiler installation no later than September 30, 2026, subject to WSIPC approval. The schedule shall identify equipment delivery, demolition, installation, reconnection, start-up, testing, and any remaining follow-up or corrective work necessary to achieve full operation.

- Worksite access is available Monday through Friday, 7:00 a.m. to 4:00 p.m. If additional hours or Saturday work are necessary to achieve the required project schedule, the contractor shall propose such hours in advance for WSIPC's review and approval.